## ADDENDUM # 1

**PROJECT**: Taste of Orland Electricity Request for Proposals

**ISSUED:** March 20, 2014

Date: March 28, 2014

To: All Proposers

From: Village of Orland Park

RE: Response to questions received

This addendum becomes part of and modifies, amends and clarifies the RFP Documents for the above mentioned project. All provisions and requirements of the RFP Documents shall remain in effect except as specifically changed below:

**Q1.** How many hours each day will each of the Generators run?

A1. 125KW (or larger) 400 amp 3 phase quiet generator – **90 hours** 30-34KW (or larger) 120/208 3 phase generator – **34 hours** 45KW (or larger) 120/208 generator – **34 hours** 

**Q2.** Can you provide a map of the tent locations?

**A2.** Attached is a copy of the 2013 Taste of Orland layout.

