



ORLAND PARK

DEVELOPMENT SERVICES DEPARTMENT
14700 RAVINIA AVENUE
ORLAND PARK, ILLINOIS 60462
708-403-5300
www.orlandpark.org

Building Code Plan Review for Interior Vehicle Display at the Orland Square Mall

CAR COMPANY _____ DATE _____
288 ORLAND SQUARE DRIVE, ORLAND PARK, ILLINOIS 60462

DATES OF VEHICLE DISPLAY _____ TO _____ (six month max) NUMBER OF VEHICLES _____

BUILDING OUTLINE/ *2015 IBC Code (as amended in the "Village Code")

The plans submitted are for interior vehicle display only.

2013 International Fire Code ® 314.0 Indoor Displays

314.1 General: Indoor displays constructed within any occupancy shall comply with Sections 314.2 through 314.4.

314.4 Vehicles: Liquid- or gas-fueled vehicles, boats or other motorcraft shall not be located indoors except as follows:

1. Batteries are disconnected.
2. Fuel in fuel tanks does not exceed one-quarter tank or 5 gallons (19 L) (whichever is least).
3. Fuel tanks and fill openings are closed and sealed to prevent tampering.
4. Vehicles, boats or other motorcraft equipment are not fueled or defueled within the building.
5. Vehicles shall not obstruct the egress path for the Mall.
6. Provide a site plan indicating a clear path around the vehicle and it's location in the Mall.
7. Permit valid for 6 months.
8. Additional inspection required for every vehicle location change or new vehicle swap.

2015 International Building Code ® 402.10 Kiosks: The minimum horizontal separation between kiosks and other structures within the mall shall be **20 feet**.

Construction plans and documents have been Reviewed for Code Compliance and approved for conformance to the provisions of the Village of Orland Park Building Code for the project referenced above by the Building Division. Final approval will be given in the field during inspection.

Applicant Printed Name

Email

Applicant Signature

Phone

Building Official

Date